

Bandankam Bhavan, 3rd floor,  
Marzban Road, Fort,  
Mumbai- 400 001.  
Fax.No.22016900  
Tel.No. 22013415/16/17  
Email: elmumbai.ce @mahapwd.com  
Date: -

2 AUG 2011

To,  
M/s Secom Services India Private Limited  
No. B-359/1, Chirag Delhi

Sub : Approval to use material on works carried out by  
Government of Maharashtra.

Ref : Your letter No. NIL Date 16.06.2011

Sir,

The subject proposal submitted by you was examined by this office and now the undersigned is pleased to accord approval to the following materials for using it on works carried out by Government of Maharashtra W.E.F. the date of issue of this letter.

Name of material	:	Early Streamer Emission Lighting Arrestor
Name & Address of the manufacture.	:	M/s. TERCEL ZEUS, 98,Glengariff Dve, Floreat WA-6014 Australia
Name & Address of the Customer	:	Secom Services India Private Limited No. B-359/1, Chirag Delhi
Brand Name	:	" Tercel "
Technical Specifications of the Materials	:	A) Impulse current test 8/20 us At 40 KA tested by CPRI Bangalore on ESE terminal Radius of Protection 1) level 1 - 37 meter to 109 meter 2) level 2 - 51 meter to 129 meter 3) level 3 - 58 meter to 140 meter
Manufactured as per ISI No..	:	IS. NO                      Year    : NO
Whether having ISI No	:	NO
License No.	:	Nil                              Validity : Nil
Whether covered by House hold Electrical	:	N.A.
Appliances Quality Control orders Manufacturing Certificate No.	:	N.A.
Validity	:	N.A.
Authority to issue M.C.	:	N.A.

The above approval is valid up to DEC - 2013 provided the performance of the material during this period remains satisfactory, In case of unsatisfactory performance; the approval accorded shall be with drawn forthwith.

Yours faithfully,



(S. T. Velkar)